

Annual Lead Testing Sample Results 2024

Test Month (2024)	ALS Reference	Address	Limit (MG/L)	Test Result
August	WP2418885	Norham Road	0.005	0.000114
August	WP2418885	Norham Road	0.005	0.000314
July	WP2418212	Norham Road	0.005	0.000864
July	WP2418212	Allenford Drive	0.005	0.000469
July	WP2418212	Pendennis Dr.	0.005	0.00108
August	WP2418778	Dalemead Cres.	0.005	0.00204
July	WP2420167	Chelwood St.	0.005	0.00128
August	WP2420151	Norham Rd.	0.005	0.00107
August	WP2420151	Dalemead Cres.	0.005	0.000051
August	WP2420264	Allenford Dr	0.005	0.000132
August	WP2420264	Chelwood Cres	0.005	0.000327
March	WP2405351	Deepdale Blvd	0.005	0.00194
August	WP2420464	Dalemead Cres.	0.005	0.000214
August	WP2420464	Allenford Dr	0.005	0.00211
September	WP2421370	Pendennis Drive	0.005	0.000297
September	WP2421370	Pendennis Drive	0.005	0.000154
October	WP2425247	Main Street	0.005	0.000513
November	WP2426170	Dalemead Cres.	0.005	0.000308
November	WP2426057	Holland Rd	0.005	0.000036
November	WP2426263	Pendennis Dr	0.005	0.00165